

**VEER SURENDRA SAI UNIVERSITY OF TECHNOLOGY, ODISHA, BURLA**  
(Formerly University College of Engineering, Burla )  
**Technical Education Quality Improvement Programme (TEQIP-II)**

P.O. Engineering College Burla,  
Dist: Sambalpur, Odisha, (India)  
PIN : 768018



Ph : 0663-2430211  
Fax : 0663-2430204  
Website : www.vssut.ac.in  
E-mail : vcvsst@gmail.com

No.VSSUT/TEQIP/ 96/2016

Dated : 10/08/2016

**QUOTATION FOR SUPPLY AND INSTALLATION OF  
VOLTAGE STABILIZER AND ISOLATION TRANSFORMER**

Sealed quotations are invited from all reputed Manufacturer / Firms/ Suppliers / Dealers / Agencies having Sales Tax Clearance for supply and installation of Voltage Stabilizer and Isolation Transformer as per specification given below by 16/08/2016 up to 5.00 PM through registered post. The quotation may be addressed to the Coordinator TEQIP Cell, VSSUT, Burla.

Sl. No.	Items	Specifications
1	Voltage Stabilizer	Capacity 15 KVA, 415 V Phase to Phase, Type: Independent Control of all the three phases Input Voltage- 310 V to 467 V phase to phase i.e. 180V – 270V/ Phase to neutral Output Voltage- 415 V Phase to Phase i.e 240 V Phase to neutral O/P V Regulation- $\pm 1\%$ per phase output voltage Termination – 5 way socket on rear door (suitable for 32 A)
2	Isolation Transformer	Capacity 15 KVA, 3/3 Phase, Primary : 415V, Operating Frequency: 50 Hz, Vacuum impregnation, Temperature Rise: Less than 40°C, Lamination: CRNGO, Termination: Terminal Strip, Termination Base: Bakelite

Sd/-

Nodal Officer, Procurement  
TEQIP, VSSUT, Burla

Memo No. VSSUT/TEQIP/ 97/2016

Dated: 10/08/2016

1. Copy to PA to Vice chancellor for kind information.
2. Copy to Steno to Registrar for information.
3. Copy to Dean F&P for uploading in the website.

Nodal Officer, Procurement  
TEQIP, VSSUT, Burla