

**VEER SURENDRA SAI UNIVERSITY OF TECHNOLOGY, ODISHA:**

**BURLA**

PO: Engineering College, Burla, Dist: Sambalpur, Odisha, India, PIN: 768018

Phone: 0663-2430211, FAX: 0663-2430204

Website: [www.vssut.ac.in](http://www.vssut.ac.in) Corresponding Mail id- [pic\\_electmaint@vssut.ac.in](mailto:pic_electmaint@vssut.ac.in)



**Quotation Call Notice**  
For

Electrical Installation Work at CRF Lab Room No A102 , PG Chemistry Lab B105& Instrument Room No- B110

QUOTATION No. VSSUT/ EM/ 587

Dated: 26/02/2021

Last Date of Submission of Quotations : 04/03/2021 at 4:00 PM

Date & time of Opening of Quotations : 05/03/2021 at 11 Hrs

1/5

**VEER SURENDRA SAI UNIVERSITY OF TECHNOLOGY, BURLA, ODISHA**

No. VSSUT/EM/

Date:

**QUOTATION CALL NOTICE**

Sealed Quotations are hereby invited from Registered Firms/ Contactors having valid Electrical contractor license and Electrical Supervisor license from Electrical Licensing board of Odisha, BBSR for E.I. work at CRF Lab Room No-A102 and PG Chemistry and Instrument Room No- B105 & B110. The sealed Quotation shall reach the office of the undersigned latest by Date: 04/03/2021, till 4.00 PM by Regd. Post/Speed Post/Courier Post only. Quotation received beyond this date line are liable to be rejected.

**Terms and Conditions:**

1. Quotation documents must be filled in on the attached Performa only on company letter head and must reach to this office by 04/03/2021, till 04.00Hrs. Under a sealed cover by registered/ speed post/Courier Post only. Any additional information you wish to provide may be attached separately and not on the attached Performa. The quotations will be opened on 05/03/2021 at 11 hours in the office of the COF/Registrar in the presence of quotationer or their authorized representative, if any.
2. Quotation received after the due date & time is liable to be rejected. Quotation by FAX/ e-mail will not be entertained.
3. The envelope containing the quotation must be super-scribed as " E.I. work at CRF Lab Room No-A102 and PG Chemistry and Instrument Room No- B105 & B110, VSSUT, Burla.
4. The Registrar reserves the right to reject any or all the quotations without assigning any reason and the decision of the university shall be final & binding.
5. The Registrar may cancel the order if it is found that the agency is black listed on previous occasions by any of the departments/ institutions/ local bodies etc.
6. **Payment terms:** a) 100% of the value of the order would be paid within 15 days on successful Electrical Installation work and on getting satisfactory report from the Prof -in-Charge, Electrical Maintenance Section of the university.
7. The supplier must submit valid up-to-date GST along with bill before release of payment.
8. The Registrar, VSSUT, Burla reserves the right to cancel the work order if the Electrical Installation work fail to meet the specifications mentioned in the order.
9. The Registrar, VSSUT, Burla reserves the right to call the firms and to conduct negotiations, if necessary.
10. Any loss/ damage during transit will be at the cost of the Firms.
11. Any dispute arising out of the deal shall be subjected to the jurisdiction of the court at Sambalpur within the state of Odisha.
12. The Quotationer shall clearly specify Transportation charges .

REGISTRAR  
V.S.S. University of Technology  
Burla, Sambalpur, Odisha-768018

2/5

13. Loading & Unloading charges shall be borne by the Concerned Firm.
14. The Quotationer shall quote quality specifications, make for electrical accessories at unit price and taxes and other duties livable, if any on the cost separately.
15. The selected Quotationer shall be requires to complete the E.I. work within 15 days of receipt of the Work order failing which the Work order shall be liable to be cancelled.
16. Submission of Quotations: Your offer in original (written in English), complete in all respect should send to Registrar, VSSUT, Burla, Sambalpur-768018 (Odisha).

**Specification for Electrical Installation Work at CRF Lab Room No-A102**

Sl.No.	Description of materials	Make	Approximate Quantity
01.	S/I of 100 Amp Panel Board Indoor type wall mount. I/C= 100 Amp MCCB make Legrand, 16 KA , 160 Amp Busbar O/g =40 Amp TPNMCB 3 Nos Including Panel Board internal wiring with three phase indicator.	Legrand/L&T	1 Set
02	S/I of 25 sq mm, 3 1/2 Core Aluminum armored Cable	Havels/ Cona/ Anchor/ Finolex/Polycab/Legrand etc.	30 Mtrs
03	S/I of Sub main wiring 2X4 sq mm + 1x 1.5 sq mm	Havels/ Cona/ Anchor/ Finolex/Polycab/Legrand etc.	30 Mtrs
04	S/I of Sub main wiring 4X4 sq mm + 2x 2.5 sq mm	Havels/ Cona/ Anchor/ Finolex/Polycab/Legrand etc.	20 Mtrs

REGISTRAR  
V.S.S. University of Technology  
Burla, Sambalpur, Odisha-768018

3/5

**Specification for Electrical Installation Work at PG Chemistry and Instrument Room No- B105 and B-110**

Sl.No	Description of materials	Make	App.Qua nity
01.	S/I of PVC Pipe 20 mm Recessed/Surface wiring to light/Fan/Exhaust fan/ Call bell point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non-metalic PVC flexible conduit with 10 Amp, 250 V modular type switch ISI marked and ceiling rose ISI marked mounted on MS box. ( Make of wire Finolex / L&T / Anchor / Havels / V Guard )	Finolex / L&T / Anchor / Havels / V Guard )	1 Set
02	(a) Group-A		02 Nos
03	(b) Group-B		02 Nos
04	(c) Group-C		10 Nos
05	S/I of 5/6A Switch & 3Pin 5/6A Socket On Existing Board.	Anchor/Legrand/Cona	02 Nos
06	S/I of 3pin 15amp Plug pt. (modular)	Anchor/Legrand/Cona	04 Nos
07	S/I of computer wiring with 3nos socket & switch. (modular)	Anchor/Legrand/Cona	02 Nos
08	<b>Circuit Sub main wiring in PVC Conduit.</b>		
09	S/I of 2 x 1.5 sq.mm + 1 x 1.5 sq.mm	Finolex/Polycab/Anchor	55 Mtrs
10	S/I of 2 x 2.5 sq.mm + 1 x 1.5 sq.mm	Finolex/Polycab/Anchor	45 Mtrs
11	S/I of 2 x 4 sq.mm + 1 x 1.5 sq.mm	Finolex/Polycab/Anchor	80 Mtrs
12	S/I of B.K Angle holder without bulb.	Anchor/Legrand/Cona	04 Nos
13	S/I of Electronic Fan Regulator(modular Step type)	Anchor/Legrand/Cona	04 Nos
14	S/I of 4 way MCB box	Anchor/Legrand/Cona	02 Nos
15	S/I of DP MCB 40 amps	Anchor/Legrand/Cona	02 Nos
16	S/I of DP MCB 32 amps	Anchor/Legrand/Cona	01 No
17	S/I of DP MCB 16 amps	Anchor/Legrand/Cona	01 No

REGISTRAR  
V.S.S. University of Technology  
Burla, Sambalpur, Odisha-768018

4/5

**Documents to be attached:**

- a) Copy of Up to date GST Clearance & PAN number.
- b) Copy of Authorized Dealership/SSI unit.
- c) Any other documents, if required

**DECLARATION:**

I hereby certify that the information furnished above is full and correct to the best of my/our knowledge. I understand that in case any deviation will be found in the above statement at any stage, the vendor will be black listed and will not be permitted to have any dealing with VSSUT, Burla in future.

Authorized Signatory of Supplier/Vendor with seal

Registrar 25.02.2021

VSSUT, Burla  
REGISTRAR  
V.S.S. University of Technology  
Burla, Sambalpur, Odisha-768018

Memo No. VSSUT/EM/

Date: 25/02/2021

Copy forwarded to the Notice Board VSSUT, Burla Dean F&P for a request to hoist the quotation call notice in the university website [www.vssut.ac.in](http://www.vssut.ac.in) for publicity. The Registrar, Sambalpur University, Jyoti Vihar Burla/Principal, VSS Medical college Hospital, Burla/ Principal GM College Sambalpur/Executive Officer, /EE GED-III, Sambalpur with request to display the above notice in their notice board for its wide publicity.

Registrar  
VSSUT, Burla

5/5